STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	495360	A. BUILDING **01 - MAIN BUILDING 01** B. WING _____	R **05/18/2018**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
THE WOODLANDS HEALTH AND REHAB CENTER	**1000 FAIRVIEW HEIGHTS** **CLIFTON FORGE, VA 24422**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS Construction Type: V(111) Number of stories: One Story Building description: The facility is a one-story building of wood construction on a concrete slab with pitched roof attics protected by sprinklers. Sprinkler Status: The building is fully sprinklered and protected by NFPA #13 wet and dry pipe systems with quick response sprinklers in patient rooms. Systems are supplied by municipal water. An unannounced LSC revisit to the standard survey conducted on 04/03/2018 was conducted on 05/18/2018 in accordance with 42 Code of Federal Regulation, Part 483: Requirements for Long Term Care Facilities. The facility was surveyed for compliance using the LSC 2012 (Existing) regulations. The facility was in compliance with the Requirements for Participation Medicare and Medicaid. Corrected deficiencies are identified on the CMS-2567B.	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.